

Inclusion of Tank Configurations as a Variable in the Cost Optimization of Branched Piped Water Networks

Nikhil Hooda, Om Damani

Department of Computer Science and Engineering, Indian Institute of Technology Bombay, Mumbai, India

Correspondence to: Om Damani (damani@cse.iitb.ac.in)

Abstract. The classic problem of the capital cost optimization of branched piped networks consists of choosing pipe diameters for each pipe in the network from a discrete set of commercially available pipe diameters. Each pipe in the network can consist of multiple segments of differing diameters. Water networks also consist of intermediate tanks that act as buffers between incoming flow from the primary source and the outgoing flow to the demand nodes. The network from the primary source to the tanks is called the primary network, and the network from the tanks to the demand nodes is called the secondary network. During the design stage, the primary and secondary networks are optimized separately with the tanks acting as demand nodes for the primary network. Typically the choice of tank locations, their elevations, and the set of demand nodes to be served by different tanks, is manually made in an ad-hoc fashion before any optimization is done. It is desirable therefore to include this tank configuration choice in the cost optimization process itself. In this work, we motivate why the choice of tank configuration is important to the design of a network and describe an Integer Linear Program (ILP) model that integrates the same to the standard pipe diameter selection problem. To aid the designers of piped water networks, the improved cost optimization formulation is incorporated in our existing network design system called JalTantra.

1 Introduction

The total capital cost of a water distribution network consists of several components like pipes, tanks, water treatment plant, et cetera. Typically only the pipe cost is considered in the cost optimization models [1,2,3,4,10]. In [9] we presented a formulation for the cost optimization of piped water networks that was optimal and fast. The solution was implemented in a water network design system called JalTantra. In this work, the scope of optimization is extended by also making the tank configuration a variable in the model. Thus our optimization metric changes from the pipe cost alone to the combined cost of pipes and tanks. This extension is also incorporated in JalTantra. Note that as in [9], the networks considered are gravity fed branched networks as is typical in rural parts of developing countries.

1.1 The Tank configuration problem

The tank configuration problem is to determine the tank locations, heights, capacities, and the downstream demand nodes that each tank will service. The purpose of using tanks is to divide the network into a primary network and secondary networks.

Primary network distributes the water from the source to the tanks. Each tank then distributes water to the demand nodes it is responsible for. This division of responsibility helps in providing a more equitable distribution of water in the entire network. Typically this choice of tank configuration is made in an ad-hoc manner, relying on the intuition and experience of the designer. In the present work, this choice is integrated in our capital cost optimization formulation and the same is implemented in the water network design software JalTantra.

Tank allocation in a network can be done in several ways. The choice can be a tank for each demand node or a single tank for the entire network or any other configuration in between these two extremes. This allocation then determines the tank capacity. The following figure depicts the two extreme configurations as well as the “optimal” one for a sample network with 6 demand nodes. Note how the choice affects the primary/secondary networks.




Figure 1: Alternate tank configurations for a sample network

1.2 The two sources of capital cost considered: Pipes and Tanks

Individual nodes in the network have water demands and minimum pressure requirements. Diameters have to be selected for the pipes connecting the nodes, such that these requirements are met. Lower the diameter, lower is the cost of the pipes, but higher the friction losses (usually referred to as headloss). If there is too much headloss in the pipes, it may lead to insufficient pressures at the demand nodes. Therefore the goal is to reduce pipe cost under the constraint of minimum pressure requirements at the demand nodes. The choice of diameter is to be made from a discrete set of commercial pipe diameters that are available. The capital cost for tanks depends on the size of the tanks to be built. However note that the cost of a tank rises sublinearly. That is, doubling the tank capacity changes the cost to less than double the original cost.

1.2 The Push and Pull of Pipes and Tanks on the Total Capital Cost

The distribution of headloss in the network dictates if the node pressure requirements are being satisfied or not. Headloss in a pipe depends on the length and diameter of the pipe used, as well as the flow through the pipe. For the branched networks, the

flow in a pipe depends on whether the pipe is part of a primary network, or a secondary network, which in turn depends on the choice of tank configurations. Typically the primary network runs for the entire day whereas secondary networks are scheduled to run for a few hours every day in order to manage the distribution of water. Thus flow rate in a secondary network is higher than that in a primary network. Therefore, for the same headloss across a pipe, higher diameters are required in case of a secondary network. This means that the total pipe cost is minimized when the entire network is a primary network, that is, there is a tank installed at each demand node, and there are no secondary networks (as is the case in the second configuration shown in figure 1).

The total tank capacity required for the network is same regardless of the tank configuration, that is, the number, locations, and the allocation of demand nodes to the tanks. The cost for various configurations, however, would be different, since as mentioned earlier, individual tank cost rises sublinearly with its capacity. Therefore the total tank cost is minimized when a single tank serves the entire network (as is the case in the first configuration shown in figure 1).

For the “tank at each demand node” configuration, the pipe cost is minimum but the tank cost is maximum compared to any alternative configuration. In the case of a single tank, the tank cost is minimum but the pipe cost is maximum. The cost optimum tank configuration therefore depends on the network topology and can lie anywhere between these two extremes. For example in the sample network shown in figure 1, the capital cost is minimized if 3 tanks are built.

In summary, the choice of tank configuration, that is, the location, height and capacity of the tanks, and the set of demand nodes that each tank serves, is a non-trivial decision that has a direct impact on the capital cost optimization of piped water networks.

The rest of the paper is structured as follows. Section 2 describes in brief the problem formulation for just the pipe diameter selection. Section 3 provides details on the extension of the formulation to include tanks. Section 4 is a brief description of the environment used to build the JalTantra system. Conclusions and future work directions are presented in Section 5.

2 The Pipe Cost Optimization Problem

Typical rural networks are branched (acyclic). Since the network is acyclic, flow in each pipe can be computed easily from the node demands. For such a system, the following optimization problem was solved in [9]:

- Input: Source node<head>, Nodes<elevation, water demand, minimum pressure requirement>, Pipe<start/end node, length>, Commercial pipe diameter<cost per unit length, roughness>
- Output: Length and diameter of segments for each pipe
- Objective: Minimize total pipe cost
- Constraints:
 - Pressure at each node must exceed minimum pressure specified
 - Water demand must be met at each node
 - Pipe diameters can only take values from provided commercial pipe diameters

2.1 The Objective Function:

The objective function (O) to be minimized is the total cost of the pipe diameters (NP – available pipe diameters) chosen for the pipes (NL – total pipes) in the network. The diameters D_{ij} can only be chosen from the set of available commercial pipe diameters. This restriction is represented via continuous variables l_{ij} which represents the length of the j^{th} pipe diameter in the i^{th} pipe. The objective function therefore is:

$$O(.) = \sum_{i=1}^{NL} \sum_{j=1}^{NP} C_{ij}(D_{ij})l_{ij}$$

2.2 Pipe constraint:

For each pipe the sum of the lengths of the various pipe diameters must equal the total pipe length L_i :

$$\sum_{j=1}^{NP} l_{ij} = L_i$$

2.3 Node constraint:

At each node n a minimum amount of pressure P_n needs to be maintained. The pressure at any node is calculated from subtracting the elevation of the node E_n and the headloss in the pipes connecting the node to the reference node (S_n) i.e. the source for the network from the head provided by the reference node H_R . The Hazen-Williams formula is used for headloss. Therefore the pressure constraint for each node n is:

$$P_n \leq H_R - E_n - \sum_{i \in S_n} \sum_{j=1}^{NP} HL'_{ij} l_{ij} \quad \text{where} \quad HL'_{ij} = \frac{10.68 * \frac{\text{flow}_i}{\text{roughness}_j}{}^{1.852}}{\text{diameter}_j{}^{4.87}}$$

3 Extension of the Formulation to include Tank Configuration

In order to include tank configuration as a variable in the model, tank cost is now included in the cost optimization. Tank cost is a piecewise linear function that is implemented using a lookup table. A binary variable e_{ij} is introduced to represent the choice of row j of the cost table for each tank i . Several constraints are introduced to include tanks as well as capture the simultaneous modelling of both the primary and secondary networks. Note that these constraints are in addition to the already described constraints of our previous model.

3.1 Introduction of Additional Variables

Several variables are added to the model to capture the choice of tank configuration.

Binary		Continuous	
f_i	flow in pipe i is primary (= 1) or secondary (= 0)	$headloss_i$	headloss in pipe i
k_{ij}	1 if node i is the source for secondary pipe j	d_n	total demand served by the tank at j^{th} node
s_{ij}	1 if the tank at i^{th} node serves the j^{th} node	$head_n$	total head at i^{th} node
e_{nj}	1 if the cost of tank at i^{th} node is calculated by the j^{th} row in the tank table	th_n	height of the tank at n^{th} node

3.2 Objective Cost:

The additional objective cost term is the tank cost at each node (NN – total number of nodes). For each tank, cost is computed using each row of the tank cost table (NE rows). Here B_j is the base cost, $Unit_j$ is the unit cost, L_j is the lower capacity and U_j is the upper capacity of row j in the tank cost table. Only one of the rows is then chosen for actual cost contribution using the binary variable e_{ij} .

$$O(.) = \sum_{i \in S \sim E} \sum_{j=1}^{NP} C_{ij}(D_{ij})l_{ij} + \sum_{n=1}^{NN} \sum_{j=1}^{NE} e_{nj} * (B_j + Unit_j * (d_n - L_j))$$

Note that the tank cost term is non-linear since it contains a product of two variables $e_{nj} * d_n$. But this term is linearizable since e_{nj} is a binary variable. z_{nj} is introduced to represent $e_{nj} * d_n$ and the following constraints are added:

$$L_j * e_{nj} \leq z_{nj} \leq U_j * e_{nj}$$

$$\sum_{n=1}^{NN} e_{nj} = 1 \quad \text{and} \quad \sum_{n=1}^{NN} z_{nj} = d_n$$

3.3 Tank Constraints

The first tank constraint is to ensure that every tank height is bounded.

$$TH_{min} \leq th_n \leq TH_{max}$$

Next the head constraint at each node is modified to include the tank height term

$$P_n \leq head_n - th_n - E_n$$

Next, are the constraints that deal with allocation of demand nodes to tanks.

If a node i does not serve its own demand i.e. it is part of a secondary network, then all its downstream nodes will also be part of a secondary network.

$$s_{ii} = 0 \Rightarrow s_{ij} = 0, \forall j \text{ downstream of } i$$

If a node i does not serve its own demand, then it cannot serve the demand of its downstream nodes.

$$s_{ii} = 0 \Rightarrow s_{ij} = 0, \forall j \text{ downstream of } i$$

For every node j , only one upstream node i (UP_j – set of all upstream nodes for node j) can serve its demand.

$$\sum_{i \in UP_j} s_{ij} = 1$$

The total demand d_i served by node i (DO_j – set of all downstream nodes for node j) is the sum of the demands of the downstream nodes that it serves.

$$d_i = \sum_{j \in DO_j} s_{ij} * Demand_j$$

For a node e , its incoming pipe will have primary flow only if the node serves itself.

$$f_i = s_{ee}$$

If s_{ij} is 1 then by definition, node i serves node j . Therefore each pipe k in the path from i to j belongs to a secondary network i.e. $f_k = 0$.

$$s_{ij} = 1 \Rightarrow f_k = 0, \quad \forall k: k \text{ is a pipe in the path between } i \text{ and } j$$

3.4 Headloss Constraints

Next, the headloss is computed for each pipe. Note that headloss for the same pipe will be different depending on whether it is part of the primary network or secondary network. The additional flow depends on the number of supply hours in the two types of networks.

$$flow_{secondary} = flow_{primary} * SecondaryFlowFactor \quad \text{where} \quad SecondaryFlowFactor = \frac{SupplyHours_{primary}}{SupplyHours_{secondary}}$$

$$HL_{primary_ij} = \frac{10.68 * \frac{flow_{primary_i}^{1.852}}{roughness_j}}{diameter_j^{4.87}} \quad HL_{secondary_ij} = \frac{10.68 * \frac{flow_{secondary_i}^{1.852}}{roughness_j}}{diameter_j^{4.87}}$$

$$HL_{ij} = HL_{primary_ij} * f_i + HL_{secondary_ij} * (1 - f_i)$$

$$headloss_i = \sum_{j=1}^{NP} HL_{ij} l_{ij}$$

Before the introduction of tanks, the “source” node provided head to the entire network. Therefore the head at each node was computed as the head provided by the source minus the sum of all headlosses along the path from the source to the node. But now each tank serves the roll of the source to the secondary network it is responsible for. The source remains responsible for the primary network. Therefore for each pipe i with a start node s and end node e :

$$\begin{aligned} head_e &= head'_{si} - headloss_i \\ head'_{si} &= (esr_s + E_s) * k_{si} + head_s * (1 - k_{si}) \\ k_{si} &= s_{ss} * (1 - f_i) \end{aligned}$$

k_{si} represents whether the secondary source of pipe i is its start node s . It is 1 only if node s serves itself and if the flow in pipe i is secondary. If k_{si} is 1 then the effective head served by node s is the sum of its elevation and the tank height. Else it is simply the head provided by the upstream source. Here note that again we have product of variables. As before, since one of the terms is binary we can linearize these constraints. The linearization is omitted here for brevity.

3.5 Results for the Sample Network

Capital cost for the sample network shown in figure 2 was optimized using the extended model. In table 1, apart from the optimal configuration, the cost breakup of the two extreme configurations, namely a single tank and tanks at each demand point, are also presented. The results are in line with expectations. The single tank configuration has the minimum tank cost and the tank at every node configuration has the minimum piping cost. The overall optimal configuration however has both tank and piping cost in the middle but an overall lower cost.

Configuration	# of tanks	Tank Cost (10^3 Rs)	Piping Cost (10^3 Rs)	Total Cost (10^3 Rs)
Single Tank	1	3703	20214	23917
Tank at every node	6	7644	14642	22286
Optimal	3	5694	16041	21735

Table 1: Cost of different Tank configurations

4 JalTantra System




Figure 2: Sample Network marked in JalTantra

The initial model used for the JalTantra system was the one laid out in [9]. It has now been extended with the tank configuration as described in the previous section. The implementation of the model includes variables and constraints dealing with parallel pipes, user defined pipe diameters/tank locations, et cetera. For brevity's sake their details have been omitted from this paper.

The implementation is done using Java 7 [7] and GLPK 4.55 [6] Linear Program Solver. Java ILP 1.2a [8] is used as the Java interface to the GLPK library. It also uses Google Maps API [5] for GIS functionality which allows the user to easily mark the network details as well as extract information like node elevation and pipe lengths. A sample use case is shown in figure 2. The system is freely available at <http://www.cse.iitb.ac.in/jaltantra> .

6 Conclusions and Future Work

The general cost optimization model of gravity fed branched piped water networks was extended by including tank configuration. The tank cost is added to the objective function along with several constraints to capture simultaneously both the primary and secondary networks created as a result of the introduction of tanks. We have incorporated our extended solution in an update of the water network design system JalTantra, available publicly at <http://www.cse.iitb.ac.in/jaltantra> .

Future work would lie in incorporating more pipe water network design components like valves and pumps. So far only a one time capital cost of the network has been considered. The addition of pumps will bring in the aspect of operational cost as well which will have to be incorporated into the objective cost.

References

- [1] Samani, Hossein MV, and Alireza Mottaghi. "Optimization of water distribution networks using integer linear programming." *Journal of Hydraulic Engineering* 132.5 (2006): 501-509.
- [2] Alperovits, E., and U. Shamir. "Design of optimal water distribution systems." *Water Resources Research* 13.6 (1977): 885-900.
- [3] Vyas, Janki H., Narendra J. Shrimali, and Mukesh A. Modi. "Optimization of Dhrafad Regional Water Supply Scheme using Branch 3.0.", *IJRSET* 2014
- [4] Yugandhara Lad, J S Main, and S D Chawathe. "Optimization of Hydraulic Design of Water Supply Tree Network Based on Present Worth Analysis." *Journal of Indian Water Works Association*. 2012
- [5] Google Maps API Reference – <https://developers.google.com/maps/documentation/javascript/reference> (May, 2016)
- [6] GLPK (GNU Linear Programming Kit) – <https://www.gnu.org/software/glpk/> (May, 2016)
- [7] Java 7 – <https://java.com/en/download/index.jsp> (September, 2014)
- [8] Java ILP, Java interface to ILP solvers – <http://javailp.sourceforge.net/> (May, 2016)
- [9] Nikhil Hooda, and Om Damani, "A System for Optimal Design of Pressure Constrained Branched Piped Water Networks", 18th Conference on Water Distribution System Analysis, WDSA (2016).
- [10] Savic, Dragan A., and Godfrey A. Walters. "Genetic algorithms for least-cost design of water distribution networks." *Journal of Water Resources Planning and Management* 123.2 (1997): 67-77.